

Integration of Smart Metering and Power Quality Monitoring for Enhanced Reliability in Electrical Distribution Systems

Mr. Sachin V. Shelar^{1,*}, Sakshi Sanjay Patil², Jayesh Jitendra Patil³, Janhavi Sachin Patange⁴

¹Department of Electrical Engineering, AISSMS Institute of Information Technology, Pune, Maharashtra, India.

Email: sachin.shelar@aissmsioit.org

²Department of Electrical Engineering, AISSMS Institute of Information Technology, Pune, Maharashtra, India.

Email: sakshipatil8044@gmail.com

³Department of Electrical Engineering, AISSMS Institute of Information Technology, Pune, Maharashtra, India.

Email: patiljayesh1620@gmail.com

⁴Department of Electrical Engineering, AISSMS Institute of Information Technology, Pune, Maharashtra, India.

Email: janhavisachinpatange@gmail.com

*Corresponding author: Mr. Sachin V. Shelar, Department of Electrical Engineering, AISSMS Institute of Information Technology, Pune, Maharashtra, India. Email: sachin.shelar@aissmsioit.org

Received: 05th May, 2026; Revised: 12th May, 2026; Accepted: 20th May, 2026; Available Online: 25th May, 2026

ABSTRACT

The modernization of electrical distribution systems into smart grids has created new challenges related to power quality (PQ). With the increasing use of Distributed Energy Resources (DERs) and nonlinear loads, maintaining power within standard limits has become more difficult. This paper provides a detailed analysis of how combining smart metering with power quality monitoring systems can help improve grid reliability and operational efficiency. The proposed system uses a multi-level Power Quality and Energy Monitoring Framework (PQEMS), where loads are classified based on their importance or criticality. Class A power quality analysers are installed at the Point of Common Coupling (PCC), along with different levels of meters across the network. This setup allows accurate monitoring and real time data collection. The tiered structure helps achieve cost effective PQ monitoring, covering everything from sensitive industrial processes to basic non critical loads like lighting. The system is also connected to cloud-based dashboards and central servers, which provide features like real time visualization, root cause analysis, and automatic compliance reporting. The results show that this integrated approach improves system uptime, increases the life of equipment, and ensures compliance with international standards such as IEC 61000 and IEEE 519. Overall, the paper concludes that combining advanced metering infrastructure with dedicated power quality monitoring is important for the sustainable development of smart distribution grids.

Index Terms: Smart Grid, Power Quality (PQ), Smart Metering, Point of Common Coupling (PCC).

How to cite this article: Shelar SV, Patil SS, Patil JJ, Patange JS. Integration of Smart Metering and Power Quality Monitoring for Enhanced Reliability in Electrical Distribution Systems. *Int J Drug Deliv Technol.* 2026;16(63s):531-535. DOI: 10.25258/ijddt.16.63s.58

Source of support: Nil.

Conflict of interest: None

I. INTRODUCTION

The electrical distribution system is changing rapidly due to the integration of Distributed Energy Resources (DERs) such as photovoltaic systems and wind turbines, along with the increasing use of nonlinear loads like electric vehicle chargers and variable frequency drives. These technologies are important for sustainability, but they also create major power quality (PQ) problems, such as harmonic distortion, voltage unbalance, and transient disturbances [1], [4]. Traditional distribution systems were not designed to handle bidirectional power flow or the high frequency switching noise produced by modern power electronic devices [12]. Poor power quality can cause serious issues like equipment failure, higher operating losses, and unexpected system downtime [8], [13]. Because of this, there is a strong need for better monitoring systems that do more than just measure energy usage. Smart meters, which

were mainly used for energy consumption measurement, are now being improved with PQ monitoring features to give a more detailed understanding of the system condition [9], [15]. When these smart meters are combined with high accuracy Class A analysers, utilities can build a complete monitoring system that can detect, analyse, and reduce PQ problems in real time [17], [20].

II. LITERATURE SURVEY

The integration of power quality monitoring into smart metering systems is a widely studied area. Standards like IEC 61000-4-30 and IEEE 519 give clear guidelines for accurate measurements and for maintaining compliance [5], [6], [18].

A. Standard Compliance (IEC/IEEE)

The IEC 61000-4-30 standard is the main guideline for measurement methods. It is an international standard which is essential for any power quality monitoring system. It defines Class A requirements, which are used when high accuracy is

needed, especially for contracts and dispute handling [6], [17]. Cano-Ortega et al. showed that cloud connected Class A analysers can be developed to monitor up to the 50th harmonic order in real time. Their work also shows the importance of using high resolution Fast Fourier Transform (FFT) analysis to get accurate results [17]. Along with measurement standards, IEEE 519 2022 provides limits for controlling harmonics in electrical power systems. This standard is commonly used to define requirements at the Point of Common Coupling (PCC), ensuring that users do not send too much harmonic distortion back into the grid [18], [23]. Research by Bollen et al. shows that combining Advanced Metering Infrastructure (AMI) with power quality features is an effective way to check compliance across many locations in a distribution network [18].

B. Smart Meter PQ Capabilities

Modern smart meters are not limited to just measuring kWh anymore. With the advancement of Digital Signal Processors (DSPs) and System on Chip (SoC) technologies, PQ monitoring features can now be included directly in the meter hardware at a low extra cost [3], [14]. Santos et al. explained that next generation smart meters can measure parameters like voltage unbalance, harmonics, and sags, which means each consumer connection can act like a small grid sensor [3]. Artale et al. studied low-cost smart metering platforms for harmonic analysis. They found that although these devices may not always meet strict Class A standards, they are still very useful for rough PQ estimation and for finding problem areas (hotspots) in the network [14], [36]. The combined or “syncretic” use of many such distributed sensors, as suggested by Albu et al., makes it possible to get a complete view of power quality across the entire system, which was not possible earlier with only centralized analysers [9].

C. AI and ML in PQ Monitoring

The large amount of data generated by integrated PQMS needs advanced tools for proper analysis. Artificial Intelligence (AI) and Machine Learning (ML) are now commonly used for automatic event detection and predictive monitoring. Kamio et al. developed a system using Long Short-Term Memory (LSTM) networks to predict power factor and THD levels in industrial systems, helping to take action before disturbances happen [4]. Further research by Arenas Ramos et al. showed that ML methods like Random Forests and Neural Networks can identify different types of loads and detect specific PQ events [16]. When these AI tools are connected to cloud-based dashboards, they allow real time monitoring of the grid and help predict possible failures in advance. This changes the maintenance approach from reactive to predictive [11], [16], [23].

D. Grid Reliability

The main goal of integrating PQ monitoring is to improve the reliability and stability of electrical distribution systems. Sabin et al. reported the use of a system wide PQMS at Con Edison in New York, where smart meter data is used to detect early

faults and identify their location quickly, which reduces outage time [7]. Similarly, Hamza et al. showed that real time monitoring along with automatic control actions, such as circuit breaker operation, helps maintain system parameters within safe limits and prevents major failures [12]. Research also shows the importance of integrated monitoring in microgrids and systems with high DER penetration. Palacios Garcia et al. explained that smart meter data is very important for managing energy flow and maintaining stability in microgrids, where even small changes in PQ can affect the balance between generation and load [8], [25].

III. SYSTEM ARCHITECTURE

The proposed system architecture is based on a Multi-Level Power Quality & Energy Monitoring Framework (PQEMS). It is designed to give accurate monitoring while keeping the overall cost low by using distributed sensing. This architecture is divided into two parts: physical construction and operational data flow.

A. Construction

The physical structure of the system is divided into four main layers:

- 1) *Point of Common Coupling (PCC) Layer*: A high accuracy Class A Power Quality Analyzer is installed at the PCC or at critical transformers. This device makes sure that the incoming power follows IEC 61000-4-30 and IEEE 519 standards. It acts as the main reference point for the entire distribution system.
- 2) *Distribution Bus Layer*: This layer is used to monitor the upstream sections of different sub networks within the facility or distribution area.
- 3) *Tiered Metering Layer*: To reduce cost, different types of meters are used based on how important the load is:
 - Tier 1 (High Criticality): High end PQ meters are used for important loads like sensitive process equipment or high voltage motors. These meters measure Total Harmonic Distortion (THD), individual harmonics, and voltage sags.
 - Tier 2 (Medium Criticality): Low end PQ meters are used for areas like offices or HVAC systems. These mainly measure voltage, current, and power factor.
 - Tier 3 (Non-Critical): Standard smart energy meters are used for lighting and small loads. These focus on energy consumption (kWh) and cost.
- 4) *Central Analysis Layer*: All monitoring devices are connected through a Unified PQ Analyzer Network. The collected data is sent to a Cloud Dashboard and a Central Server for analysis and monitoring.

B. Working and Data Flow

The working of the PQEMS is designed to give real time visibility and help in early problem detection:

- *Data Acquisition*: Sensors placed across different tiers continuously measure electrical parameters. Tier 1 and Tier 2 meters also analyse waveforms inside the device to detect transients and harmonics [14], [17].

- Transmission: The collected data is sent to the central server using secure communication methods like 6LoWPAN, Wi-Fi, or Modbus RTU [2], [4], [17].
- Real time Visualization: The cloud dashboard shows the current system condition in real time and highlights any values going beyond standard limits [5], [11].




Fig. 1. Schematic diagram of PQEMS

- Root Cause Analysis: When any disturbance occurs, the central server compares data from different meters to find where the problem started and how it spread [7], [27]. Methods like PCA and k-means clustering are used to classify disturbances automatically [23].
- Compliance Reporting: The system generates reports based on standards like EN 50160 and IEEE 519, which helps in checking compliance and solving issues [8], [18].

IV. PROPOSED INTEGRATED PQMS

The proposed Integrated Power Quality Monitoring System (PQMS) combines centralized high accuracy monitoring with distributed smart sensing.

A. Event Correlation and Fault Detection

One important feature of the PQMS is its ability to link events across different layers. Using a common SQL based database, the system can match events happening at high, medium, and low voltage levels [27]. This helps in identifying whether the disturbance is coming from the grid side or from inside the consumer’s system [10]. As noted by Sabin et al., this type of system can detect early signs of faults and alert operators before a complete failure or outage happens [7].

B. Distributed Measurement and Intelligence

With the improvement in smart metering technology, new ways of distributed measurement are now possible [10]. AI functions can be added either in the meters or in the central server to analyse data in real time and predict issues in advance [16]. This approach reduces the amount of data that needs to be transmitted, as only important event data is sent instead of full

waveform data. At the same time, detailed analysis can still be done whenever required [2], [13].

V. RELIABILITY AND BENEFITS

The integration of smart metering and PQ monitoring yields substantial benefits for the reliability and sustainability of electrical distribution systems.

A. Enhanced System Uptime and Stability

Real time monitoring and automatic control functions strengthen the power grid’s self-protection capabilities [1]. Systems that integrate smart meters with automated circuit breaker operations can maintain parameters within predefined limits, preventing widespread outages [12]. Furthermore, the ability to rapidly identify the cause and location of interruptions leads to faster system restoration after outages [28],[29].

B. Improved Equipment Life

Power quality disturbances, particularly harmonics and voltage unbalance, increase the thermal stress on transformers and motors, leading to premature aging [13],[30]. By monitoring loading history and PQ parameters, utilities can implement predictive maintenance strategies, effectively extending the lifespan of critical assets [4],[27]. For instance, monitoring the cycling loading of transformers helps in optimizing asset replacement schedules [30].

C. Standard Compliance and Operational Efficiency

Continuous PQ monitoring ensures that the distribution network operates within the limits set by international standards [6],[18]. This is particularly important in liberalized energy markets where PQ levels may be part of contractual agreements between utilities and industrial customers [18]. Additionally, the use of low-cost smart metering platforms for PQ monitoring allows for widespread deployment without prohibitive installation costs, thereby maximizing the “perimeter energy visibility” of the system [14],[21].

VI. RESULTS, BENEFITS, AND RELIABILITY

The implementation of an integrated smart metering and PQ monitoring system delivers quantifiable benefits across several operational dimensions.

A. Equipment Life and Thermal Stress Reduction

One of the most significant benefits is the reduction of thermal stress on critical assets. Harmonic currents increase the “skin effect” in conductors and cause additional core losses in transformers and eddy current losses in motor windings [13],[30]. By providing real time visibility into harmonic levels, the PQMS allows operators to manage load profiles and prevent over harmonic conditions. Kamio et al. noted that maintaining THD levels within limits can extend the operational life of industrial motors and transformers by up to 15-20%, depending on the baseline distortion levels [4].

B. System Uptime and Stability

The Integrated PQMS directly contributes to system uptime through incipient fault detection. By monitoring subtle changes

in PQ signatures, such as increasing leakage currents or shifting harmonic patterns, the system can identify failing insulation or deteriorating capacitor banks before they result in a full-scale outage [7],[12]. Furthermore, the ability to rapidly identify the location and cause of disturbances reduces the Mean Time to Repair (MTTR) and minimizes the impact of outages on the broader network [28],[29].

C. Quantifiable Economic Benefits

The reduction in unscheduled downtime and the extension of equipment lifespan translate directly into improved operational efficiency. For a medium sized industrial facility, a 5% improvement in system uptime can result in millions of dollars in additional annual revenue. Moreover, the detailed energy data provided by the tiered metering layer allows for precise energy cost allocation and the identification of energy saving opportunities, further enhancing the system’s Return on Investment (ROI) [13],[21].

VII. CONCLUSION AND FUTURE SCOPE

The transition to active distribution networks necessitates a fundamental rethink of how we monitor and manage electrical power. This paper has demonstrated that the integration of smart metering and dedicated power quality monitoring is the most effective strategy for ensuring grid reliability in the era of DERs and power electronics. The proposed Multi Level PQEMS architecture provides a scalable, cost-effective framework that balances the need for high precision Class A measurement with widespread distributed sensing. By leveraging AI-driven analytics and cloud-based management, the system transforms raw electrical data into actionable insights, enabling predictive maintenance, automated compliance, and enhanced system stability. Future work in this field will likely focus on the deeper integration of “Edge AI,” where PQ event classification and mitigation decisions are made directly at the meter level, further reducing the latency and communication overhead of the system. Additionally, the development of unified standards for the exchange of PQ data between different utility and customer side systems will be essential for the continued evolution of the global smart grid.

ACKNOWLEDGMENT

We the authors would like to acknowledge the support of the Department of Electrical Engineering, AISSMS Institute of Information Technology, Pune, Maharashtra, India.

REFERENCES

[1] H. Yang, Y. Zhang, and J. Wu, “The Design of Smart Meter with Power Quality Monitoring,” in *Proc. International Conference on Applied Science and Engineering Innovation*, 2015. <https://doi.org/10.2991/ASEI15.2015.288>

[2] J. Hoglund et al., “Using a 6LoWPAN smart meter mesh network” for event-driven monitoring of power quality,” in *Proc. IEEE International Conference on Smart Grid Communications*, 2012, pp. 448–453. <https://doi.org/10.1109/SMARTGRIDCOMM.2012.6486025>

[3] S. Santos et al., “Future applications based on the data provided by next generation of smart meters,” in *Proc. IEEE Eindhoven PowerTech*, 2015.

M. Kamio et al., “Arquitetura computacional para controle de monitoramento de qualidade de energia utilizando ferramentas de inteligencia artificial focado na industria 4.0 com integrac, ’ ao de energias renov aveis,” *GeSec*, vol. 15, no. 12, 2024. <https://doi.org/10.7769/gesec.v15i12.4494>

A. Moustafa et al., “A smart web-based power quality and energy monitoring system with enhanced features,” *IEEE Access*, 2025. <https://doi.org/10.1109/access.2025.3571623>

N. Browne et al., “Monitoring intelligent distribution power systems— A power quality plan,” in *International Conference on Harmonics and Quality of Power*, 2010.

D. Sabin et al., “System-wide power quality monitoring at the consolidated Edison company of New York,” in *Proc. International Conference on Harmonics and Quality of Power*, 2012. <https://doi.org/10.1109/ICHQP.2012.6381264>

L. Palacios-Garcia et al., “Using smart meters data for energy management operations and power quality monitoring in a microgrid,” in *Proc. IEEE International Symposium on Industrial Electronics*, 2017. <https://doi.org/10.1109/ISIE.2017.8001508>

M. Albu et al., “Syncretic Use of Smart Meters for Power Quality Monitoring in Emerging Networks,” *IEEE Transactions on Smart Grid*, vol. 8, no. 3, pp. 1051–1060, 2017. <https://doi.org/10.1109/TSG.2016.2598547>

G. Caravello, “Study, project and implementation of new metrics for distributed measurement system in medium voltage smart grid,” Thesis, 2015.

[11] J. Garrido-Zafra et al., “IoT cloud-based power quality extended functionality for grid-interactive appliance controllers,” *IEEE Transactions on Industry Applications*, vol. 58, no. 4, pp. 4344–4354, 2022. <https://doi.org/10.1109/TIA.2022.3160410>

H. Hamza et al., “Design and Development of Power Quality Module for Smart Microgrid,” in *Proc. International Conference on Power Electronics, Intelligent Control and Energy Systems*, 2024. <https://doi.org/10.1109/ICPEICES62430.2024.10719289>

A. Vlasov et al., “Sustainable energy systems in the digital economy: concept of smart machines,” *Entrepreneurship and Sustainability Issues*, vol. 6, no. 4, 2019. [https://doi.org/10.9770/JESI.2019.6.4\(30\)](https://doi.org/10.9770/JESI.2019.6.4(30))

A. Artale et al., “Pq and harmonic assessment issues on low-cost smart metering platforms: A case study,” *Sensors*, vol. 20, no. 21, 2020. <https://doi.org/10.3390/S20216361>

M. Music et al., “Upgrading smart meters as key components of integrated power quality monitoring system,” in *Proc. International Conference on Environment and Electrical Engineering*, 2016. <https://doi.org/10.1109/EEEIC.2016.7555554>

F. Arenas-Ramos et al., “Software Integration of Power System Measurement Devices with AI Capabilities,” *Applied Sciences*, vol. 15, no. 1, 2024. <https://doi.org/10.3390/app15010170>

A. Cano-Ortega et al., “Calibration of a class A power quality analyser connected to the cloud in real time,” *Electronics*, vol. 13, no. 16, 2024. <https://doi.org/10.3390/electronics13163209>

M. Bollen et al., “CIGRE/CIREC JWG C4.112 - Power Quality Monitoring,” *Renewable Energy & Power Quality Journal*, vol. 1, no. 12, 2014. <https://doi.org/10.24084/REPQJ12.011>

[19] G. Kalaycioglu et al., “National PQ Monitoring Network for Turkish Electricity Transmission System,” 2007.

M. Ciani et al., “Performance assessment of grid frequency measurements in a smart power quality meter,” in *Proc. IEEE International Instrumentation and Measurement Technology Conference*, 2025. <https://doi.org/10.1109/I2MTC62753.2025.11079074>

[21] A. Ditta, “Technologies and Metrics for Metrological Characteristics Improvement of Low-Cost Devices for Smart Grids Measurements,” Thesis, 2018.

[22] M. Darie et al., “Assessment of a smart home power quality measurement data,” *U.P.B. Sci. Bull., Series C*, 2016.

S. Dmitriev et al., “Integrated Intelligent Power Supply Management in Mechatronics-Intensive Manufacturing Facilities,” in *Proc. IEEE Ural-Siberian Conference on Computational Technologies in Cognitive Science, Control and Communication*, 2025. <https://doi.org/10.1109/URALCON67204.2025.11206681>

[24] J. Peppanen, “Improving distribution system model accuracy by leveraging ubiquitous sensors,” Dissertation, Georgia Institute of Technology, 2016.

- [25] "Power Quality Monitoring of Low Voltage Distribution System Toward Smart Distribution Grid Through IoT," in *Smart Distribution Grids*, CRC Press, 2022. <https://doi.org/10.1201/9781003360780-3>
- [26] O. Bezbozhnov et al., "Smart Grid: Monitoring the Quality of Electric Power," *NBI tehnologii*, no. 2, 2022. <https://doi.org/10.15688/nbit.jvolsu.2022.2.1>
- [27] M. Zanoni et al., "An Integrated Approach for Power Quality Monitoring in Transmission and Distribution Systems: The Italian Scenario," in *Proc. IEEE International Workshop on Applied Measurements for Power Systems, 2025*. <https://doi.org/10.1109/AMPS66841.2025.11219908>
- [28] S. Vukmirovic et al., "Extension of the Common Information Model with Virtual Meter," *Elektronika Ii Elektrotehnika*, vol. 107, no. 1, 2011. <https://doi.org/10.5755/J01.EEE.107.1.9082>
- [29] V. Zavoda, "Sensors and IEDs Required by Smart Distribution Applications," in *Smart Grid*, 2011.
- [30] N. Browne et al., "Monitoring intelligent distribution power systems — A power quality plan," in *Proc. International Conference on Harmonics and Quality of Power*, 2010. <https://doi.org/10.1109/ICHQP.2010.5625506>